

Draft Planning Assumptions by Outage State⁴

Feb 3, 2015

Study	Forced Out	Inactive Reserve ⁵	ICAP Ineligible Forced Outage	Intent to mothball or retire	Mothball	Mothball Noticed Intent to Return	Retired³
IRM^{1,2}	In unless Case specific reason to remove Note: ICS could chose to do a sensitivity study	In	Treat as mothball units, add to Appendix C Policy 5 ⁶ (Need to consider timing and notification issues)	See Appendix C Policy 5	See Appendix C Policy 5	See Appendix C Policy 5	Out

Notes:

1. The status of the generator will be based on the status at the time of the assumption lock down of the specific study. If the status changes during the study, then it may be noted in the study report, as appropriate.
2. In limited situations, the initial study scope could include an alternative generator status as a sensitivity case.
3. Retired units returning to service must be treated as a new unit and will be subject to evaluation as such in the interconnection process.
4. The treatment of RMR units needs to be included in NYSRC's Appendix C Policy 5. NYISO recommends that the unit should be treated as in if it is expected during the capability period of the IRM study.
5. The treatment of a unit in Inactive Reserve needs to be included in NYSRC's Appendix C Policy 5. NYISO recommends that the unit should be assumed in because it is an elective status and the unit would be eligible to return by the next capability period.
6. NYISO will be suggesting updates to Appendix C, Policy 5 for consideration at ICS.