

Preliminary Base Case

<u>Case Number</u>	<u>Description</u>	NYCA	Zone J	Zone K
		<u>RM</u>	<u>RM</u>	<u>RM</u>
	IRM 2016 Final Base Case	17.4	80.8	102.4
0	Run Initial Base Case check	17.4	80.8	102.4
1	MARS Version 3.20 w/wo H5 load shape	17.4	80.8	102.4
2	PJM 4 vs. 5 bubble model	17.3	80.7	102.3
3	Retirements	18.6	79.7	102.5
4	Multiple Wind Shapes	18.4	79.7	102.5
5	Add Marble River + Orangeville Rerate	19.0	79.7	102.5
6	Multiple Solar Shapes	19.0	79.7	102.5
7	Gold Book Forecast 2017	18.5	79.2	102.7
8	Cable Transition Rates	18.6	79.2	102.8
9	Gen Transition Rates	19.2	79.7	103.4
10	Update non-SCR EOPs	19.1	79.7	102.3
11	Update SCRs			
12	Gold Book DMNCs			
13	Maintenance Changes (locational change)			
14	Small Hydro Derate change if needed			
15	Remove PSEG/Con Ed Wheel			
16	Upstate NY topology			
17	Update PJM (Loads and Caps)			
18	Update Ontario, Quebec, and NE			