Attachment #4.2.1 Return to Agenda

Figure 24: Statewide System Margin (Summer Peak - Expected Weather, Normal Transfer Criteria) (Note, may not exactly match NYISO Table due to rounding)

		Summer Peak - Baseline Expected Summer Weather, Normal Transfer Criteria (MW)									
Line	Item	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033
А	NYCA Generation (1) (ICAP)	38,066	38,343	38,266	38,266	38,266	38,266	38,266	38,266	38,266	38,266
В	NYCA Generation Derates (2)	(5,863)	(6,567)	(6,582)	(6,596)	(6,610)	(6,624)	(6,624)	(6,639)	(6,653)	(6,653)
С	Temperatures Based Generation Derates	0	0	0	0	0	0	0	0	0	0
D	External Area Interchanges(3)	1,844	1,844	3,094	3,094	3,094	3,094	3,094	3,094	3,094	3,094
E	Total Resources (A+B+C+D)	34,047	33,620	34,778	34,764	34,750	34,736	34,736	34,721	34,707	34,707
F	Demand Forecast (5)	(31,763)	(31,626)	(31,436)	(31,292)	(31,164)	(31,126)	(31,266)	(31,526)	(31,886)	(32,296)
G	Large Load Forecst (6)	(517)	(764)	(1,004)	(1,118)	(1,146)	(1,174)	(1,224)	(1,224)	(1,224)	(1,224)
Н	Largest Loss-of-Source Contingency	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
I	Total Capability Requirement (F+G) (UCAP)	(33,590)	(33,700)	(33,750)	(33,720)	(33,620)	(33,610)	(33,800)	(34,060)	(34,420)	(34,830)
J	Statewide System Margin (E+I)	457	(80)	1,028	1,044	1,130	1,126	936	661	287	(123)
К	Higher Policy Demand Impact	75	160	190	(30)	(320)	(570)	(720)	(940)	(1,060)	(1,220)
L	Higher Policy Statewide System Margin (J+K)	532	80	1,218	1,014	810	556	216	(279)	(773)	(1,343)
Μ	SCRS (7), (8)	897	897	897	897	897	897	897	897	897	897
N											
0	Operating Reserve	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)	(1,310)
Р	Statewide System Margin with Full Operating Reserves (I+J) (4) (UCAP)	(853)	(1,390)	(282)	(266)	(180)	(184)	(374)	(649)	(1,023)	(1,433)

Notes:

1. Reflects the 2023 Gold Book existing summer capacity plus projected additions and deactivations.

2. Reflects the derates for generating resources. For this evaluation land-based wind generation is assumed to have a capability of 5% of the total nameplate, off-shore wind at 10% of the total nameplate, solar generation is based on the ratio of solar PV nameplate capacity (2023 Gold Book Table I-9a) and solar PV peak reductions (2023 Gold Book Table I-9c). Derates for run-of-river hydro are included as well as the Oswego Export limit for all lines in-service. Includes derates for thermal resources based on NERC five-year class average EFORd data published August 2022

(https://www.nerc.com/pa/RAPA/gads/Pages/Reports.aspx).

3. Interchanges are based on ERAG MMWG values.

4. For informational purposes.

5. Reflects the 2023 Gold Bood Forecast without the impact of the large load queue projects included.

6. Forecast of large load queue projects inlued in this assessmenty (Q0580 – WNY STAMP, Q0776 – Greenidge, Q0849 – Somerset, Q0580 – Cayuga, Q0979 – North Country Data Center, Q1536 - White Pines Phas (Micron), and Q1446 - Massena Green Hydrogen (Air Products and Chemicals)).

7. SCRs are not applied for transmission security analysis of normal operations, but are included for emergency operations.

8. Includes a derate of 384 MW for SCRs

Resource A	Adequacy Equivalent										
L	Capacity From Above (A+D)	39,910	40,187	41,360	41,360	41,360	41,360	41,360	41,360	41,360	41,360
М	System EFORd (-B/A)	15.4%	17.1%	17.2%	17.2%	17.3%	17.3%	17.3%	17.3%	17.4%	17.4%
Ν	ICAP Equivalent of System Margin (I/(1-M))	540	-97	1242	1261	1366	1362	1132	800	347	-149
0	Required Minimum Capacity From Above	39,370	40,284	40,118	40,099	39,994	39,998	40,228	40,560	41,013	41,509
Resource A	Adequacy Capacity Not Included In Analysis Above										
Р	Special Case Resources (2024-2025 IRM Study Assumptions Attachment F)	1,281	1,281	1,281	1,281	1,281	1,281	1,281	1,281	1,281	1,281
R	Total Minimum Installed Capacity Requirement (O+P+Q)	40,651	41,565	41,399	41,380	41,275	41,279	41,509	41,841	42,294	42,790
S	Implicit Minimum Installed Reserve Margin (R/F - 1)	25.9%	28.3%	27.6%	27.7%	27.7%	27.8%	27.8%	27.8%	27.7%	27.7%