

List of Potential Reliability Rule Changes - Outstanding						
Categories: R = Rule; D = Definition; RO = Requirement; P = Procedure/Guideline; C = Compliance Elements; E = Exception						
Status: 1=In RRS for development/review 2=In RCMS for compliance elements 3=To EC for approval to post 4=Approved by EC for posting 5=RRS incorporating comments from posting 6=To EC for final approval 7=Approved by EC 8=Removed						
PRR No.	Existing Rule	Potential Rule Change	Sponsor	Category	Status	RRS Action
PRR 150	New Rule: Resource Adequacy Requirements for Mitigating the Threats of Extreme Weather	R1. NYISO Extreme Weather Resilience Operating Plan. R2. Operation During Impending Severe Weather. R3. NYCA Long Term Extreme Weather Resource Adequacy Assessments.	RRS	R	1	In development
PRR 151	New Rule: NYCA Interconnection Standards for Large Facility Inverter Based Resources	R1. NYISO shall prepare and maintain procedures for Large IBR Generating Facility interconnection studies based on IEEE Standard 2800-2022. R2. NYISO shall develop procedures for coordination of Transmission Owner's IBR interconnection requirements with requirement R1. R3. NYISO shall develop procedures for ensuring Large IBR Generating Facility's compliance with requirement R1. R4. NYISO shall annually prepare a technical report documenting compliance with requirements R1, R2 & R3. R5. Each Transmission Owner shall provide their IBR interconnection requirements to NYISO. R6. Each Large IBR Generating Facility owner shall provide all applicable IBR models, data, validation and performance criteria to NYISO per requirement R1.	RRS	R/P	7	Approval by EC 2-9-24
PRR 153	New Contingency requirement for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1	NYISO/RRS/ EW WG	R	1	In development

New York State Reliability Council - Reliability Rules Subcommittee

PRR 153a	New Contingency requirement for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include "Sudden loss of gas fuel to a plant for common mode failure of gas delivery system" as Category I & II Design Contingencies in Table B-1	NYISO/RRS/ EW WG	R	3	RRS recommended EC approval to post for comments 2-29-24
PRR 154	New System Condition for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include a system conditions of "Peak load resulting from extreme weather & generating unit fuel shortages under expected weather" for Category I Design Contingencies in Table B-1	NYISO/RRS/ EW WG	R	1	Superseded by PRR 154a
PRR 154a	New System Condition for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include a system condition of "Unavailability of generating units due to gas shortage" for Category I Design Contingencies in Table B-1	NYISO/RRS/ EW WG	R	3	RRS recommended EC approval to post for comments 2-29-24