

**NEW YORK STATE RELIABILITY COUNCIL  
EC #301 – Friday May 10, 2024**

**Status Report - RRS Meeting #287 – Thursday May 2, 2024**

- **PRRs under Development**
  - PRR 150 - "Resource Adequacy Requirements for mitigating the threats of extreme weather". Retired following review of NYISO's current procedures and ICS 2024 goals
  - PRR 153 - TS Planning Performance Requirements - Include "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1. Continued discussion on definition of "lull" contingencies.
- **PRRs Posted for Comment**
  - None
- **PRRs Under Review following Posting**
  - None
- **PRRs for Final Approval**
  - PRR 153a - TS Planning Performance Requirements - Include "Sudden loss of gas fuel to a plant for common mode failure of gas delivery system" as Category I & II Design Contingencies in Table B-1. RRS recommended EC final approval, no comments received.
  - PRR 154a - TS Planning Performance Requirements - Include a system condition of "Unavailability of generating units due to gas shortage" for Category I Design Contingencies in Table B-1. RRS recommended EC final approval, no comments received.
- **Other RRS Matters**
  - None
- **Next Meeting RRS #288**
  - Thursday June 6, 2024 @ 10:00 am (WEBEX)