

List of Potential Reliability Rule Changes - Outstanding						
Categories: R = Rule; D = Definition; RO = Requirement; P = Procedure/Guideline; C = Compliance Elements; F = Exemption						
Status: 1=In RRS for development/review 2=In RCMS for compliance elements 3=To EC for approval to post 4=Approved by EC for posting 5=RRS incorporating comments from posting 6=To EC for final approval 7=Approved by EC 8=Removed						
PRR No.	Existing Rule	Potential Rule Change	Sponsor	Category	Status	RRS Action
PRR 150	New Rule: Resource Adequacy Requirements for Mitigating the Threats of Extreme Weather	R1. NYISO Extreme Weather Resilience Operating Plan. Operation During Impending Severe Weather. Long Term Extreme Weather Resource Adequacy Assessments. R2. R3. NYCA	RRS	R	8	Retired
PRR 153	New Contingency requirement for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1	NYISO/RRS/ EW WG	R	1	In development

New York State Reliability Council - Reliability Rules Subcommittee

PRR 153a	New Contingency requirement for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include "Sudden loss of gas fuel to a plant for common mode failure of gas delivery system" as Category I & II Design Contingencies in Table B-1	NYISO/RRS/ EW WG	R	6	RRS recommended EC final approval
PRR 154a	New System Condition for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include a system condition of "Unavailability of generating units due to gas shortage" for Category I Design Contingencies in Table B-1	NYISO/RRS/ EW WG	R	6	RRS recommended EC final approval