NYISO OPERATIONS REPORT FOR the Month of April 2024

Peak Load

The peak load for the month was 19,019 MW, which occurred Wednesday, April 3, 2024, for hour beginning 17:00. At that time, the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 20,984 MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,303	2,506	4,101
DSASP Cont.	375	0	375

The NYCA all time Winter peak load of 25,738 MW, which occurred on Tuesday, January 7, 2014 for hour beginning 18:00

Major Emergencies

None

The Major Emergency state was declared 0 times during April of 2023

Alert States

- ON 1 OCCASIONS AN ALERT STATE WAS DECLARED:
 - 1 SYSTEM FREQUENCY 1 LOW 0 HIGH
 - 0 ACE GREATER THAN (+OR-) 500MW
 - 0 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
 - 0 SHORTAGE OF 10 MIN TOTAL RESERVE
 - 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
 - 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
 - 0 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
 - 0 EXCEEDING TRANSIENT STABILITY LIMIT
 - 0 NYISO COMPUTER PROBLEM
 - 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
 - 0 EMERGENCY TRANSFER DECLARED
 - 0 GIC (SMD) ACTIVITY
 - 0 SEVERE WEATHER
 - 0 OTHER

The Alert state was declared 7 times during April of 2023

Thunder Storm Alerts

4 Thunder Storm Alerts were declared for the month of April for a total of 8 hours

Reserve Activations

- ON 6 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:
 - 2 LOSS OF NEW YORK CONTROL AREA GENERATORS
 - 0 MAINTENANCE OF SYNCHRONIZED RESERVES
 - 2 SIMULTANEOUS ACTIVATION OF RESERVES
 - 0 FOR ISO-NE
 - 2 FOR IESO
 - 0 FOR PJM
 - 0 FOR NYISO
 - 0 FOR NB
 - 2 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 2 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - **0** OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)
- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 0 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF APRIL 2023

0 OF THESE PICKUPS WHERE FOR ACE.

Emergency Actions

Special Case Resources:	None
Emergency Demand Response Program:	None
Purchases:	None
Sales:	None

TLR 3 Declared

0 TLR Level 3's were declared for the month of April for a total of 0 hours

Inadvertent Accumulations for	Marc	<u>h 2024</u>		
	Monthly		End of Month	
	<u>Accumula</u>	<u>tion</u>	Balance	<u>e</u>
On-Peak:	12,722	MWh	-4,676	MWh
Off-Peak:	9,527	MWh	2,386	MWh

NERC Control Performance

CPS1:	145.08 %
BAAL VIOLATIONS:	0

NERC/NPCC Reportable DCS Events

None