

Exception Reference No.	TO	Exception Category	Exception	NYSRC Reliability Rule
1	NYPA	Run Back of Generators	<p><b>Post Contingency Flow on Marcy-New Scotland</b></p> <p>Post-contingency flow on the Marcy-New Scotland 18 line is allowed to exceed its LTE rating , without going above its STE rating, for either:</p> <ul style="list-style-type: none"> <li>• the loss of the Edic- Gordon Road 14 line,</li> <li>• or the double-circuit loss of the Edic-Princetown 351 and 352,</li> </ul> <p>by the amount of relief that can be obtained by tripping the Gilboa pumping load as a single corrective action.</p> <p>Also, the post-contingency flow on the Edic- Gordon Road 14 line is allowed to exceed its LTE rating, without going above its STE rating, for either:</p> <ul style="list-style-type: none"> <li>• the loss of the Marcy-New Scotland 18 line alone,</li> <li>• or the double-circuit loss of the Marcy-New Scotland 18 and Adirondack-Porter 12 lines.</li> </ul> <p>by the amount of relief that can be obtained by tripping the Gilboa pumping load as a single corrective action.</p>	C.1

Also, the post-contingency flow on the Princetown-New Scotland 55 line is allowed to exceed its LTE rating, without going above its STE rating, for either:

- the loss of the Marcy-New Scotland 18 line alone, or the double-circuit loss of the Marcy-New Scotland 18 and Adirondack-Porter 12 lines,
- or the double-circuit loss of the Princetown-New Scotland 361 and 362.

by the amount of relief that can be obtained by tripping the Gilboa pumping load as a single corrective action.

*Approved NYSRC MMDDYR.*