# NYISO OPERATIONS REPORT FOR the Month of June 2024

## Peak Load

The peak load for the month was 28,245 MW, which occurred Friday, June 21, 2024, for hour beginning 15:00. At that time the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 30,210 MW for that hour.

**Reserve Requirements:** 

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	2,615	3,385	4,790
DSASP Cont.	236	0	236

The NYCA all time Summer Peak Load of 33,956 MW, which occurred on Friday, July 19, 2013 for hour beginning 16:00.

## Major Emergencies

None

The Major Emergency state was declared 0 times during June of 2023

## Alert States

- ON **4** OCCASIONS AN ALERT STATE WAS DECLARED:
  - 1 SYSTEM FREQUENCY 1 LOW 0 HIGH
  - **3** ACE GREATER THAN (+OR-) 500MW
  - **0** SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
  - 0 SHORTAGE OF 10 MIN TOTAL RESERVE
  - 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
  - 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
  - 0 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
  - 0 EXCEEDING TRANSIENT STABILITY LIMIT
  - 0 NYISO COMPUTER PROBLEM
  - 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
  - 0 EMERGENCY TRANSFER DECLARED
  - 0 GIC (SMD) ACTIVITY
  - 0 SEVERE WEATHER
  - 0 OTHER

The Alert state was declared 2 times during June of 2023

## Thunder Storm Alerts

**9** Thunder Storm Alerts were declared for the month of June for a total of 48.9 hours

## **Reserve Activations**

- ON 6 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH:
  - 4 LOSS OF NEW YORK CONTROL AREA GENERATORS
  - 0 MAINTENANCE OF SYNCHRONIZED RESERVES
  - 3 SIMULTANEOUS ACTIVATION OF RESERVES
    - 1 FOR ISO-NE
    - 0 FOR IESO
    - 1 FOR PJM
    - 1 FOR NYISO
    - 0 FOR NB
  - 0 LARGE CONTROL ERRORS (ABOVE 200MW)
    - 0 LOAD PICKUP
    - 0 SCHEDULE CHANGE & LOAD PICKUP
    - 0 SCHEDULE CHANGE
    - 0 SCHEDULE CHANGE DUE TO TLR
    - 0 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)
- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS

ON 5 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF JUNE 2023 2 OF THESE PICKUPS WHERE FOR ACE.

#### **Emergency Actions**

Special Case Resources: Emergency Demand Response Program: Purchases: Sales: Zone K 6/20/2024 15:00-19:00 Zone K 6/20/2024 15:00-19:00 None None

## TLR 3 Declared

**0** TLR Level 3's were declared for the month of June for a total of 0 hours

## Inadvertent Accumulations for May 2024

	Monthly		End of Month		
	<u>Accumulati</u>	Accumulation		<u>Balance</u>	
On-Peak:	-12,950	MWh	-18,535	MWh	
Off-Peak:	-7,944	MWh	-2,677	MWh	

#### **NERC Control Performance**

CPS1: 154.17 % BAAL VIOLATIONS: 0

#### **NERC/NPCC Reportable DCS Events**

On 06/18/2024 a SAR was initiated at 22:07 and a RPU was initiated at 22:09 for the loss of HQ 7040 loaded at 934 MW. ACE crossed zero and the RPU was termindated at 22:14. SAR was terminated at 22:22.