

# NYISO Self-Certification

**NYSRC Reliability Rule:**

**D.1: Mitigation of Major Emergencies**

**NYSRC Requirement(s) for which compliance is being self-certified:**

**R8.** The NYISO shall maintain procedures and systems that ensure that appropriate actions are taken when frequency, reserves, thermal, voltage, and/or stability limits are violated in accordance with R1 through R7. The NYISO must notify the NYSRC of any changes to these procedures and systems.

**Compliance Monitoring Process**

**Compliance Monitoring Responsibility:**

- M1: RCMS

**Compliance Documentation Reporting Frequency:**

- M1: In accordance with *NYSRC* Compliance Monitoring Program schedule.

**Compliance Reporting Requirements:**

- M1: *NYISO* Self-Certification. This may be supplemented, if determined by the *NYSRC*, by audits or other information specified by the *NYSRC* Compliance Monitoring Program, or other requirements determined by the *NYSRC*.

**Measure No.**

<input checked="" type="checkbox"/> Full Compliance	M1. The NYISO maintained procedures and systems in accordance with R8 that ensures all Market Participants will respond correctly when frequency, reserves and thermal, voltage and/or stability limits are violated, as required by R1 through R7.
---	---

**Levels of Non-Compliance**

___ Level 1	M1. Not applicable.
___ Level 2	M1. <i>NYISO</i> procedures were provided but were incomplete in one or more areas.
___ Level 3	M1. Not applicable.
___ Level 4	M1. Procedures were not provided by the <i>NYISO</i> .

## **Reliability Rule D.1 (R1-R8) Narrative**

**R8:** The NYISO Emergency Operations Manual section 4 - Monitored Conditions – contains the NYISO actions taken when frequency, reserves, thermal, voltage, and/or stability limits are exceeded.

**R1:** Transmission Thermal Overloads is referenced in the Emergency Operations Manual (EOM) in Section 4.1

**R2:** Post Contingency STE Rating Exceedances is referenced in the EOM in Section 4.1.2.

**R3:** High or Low Voltage is referenced in the EOM in Section 3.3 and 4.2

**R4:** Post Contingency Voltage IROL Exceedances is referenced in the EOM in Section 3.3 and 4.3

**R5:** Operating Reserve Deficiency is referenced in the EOM in Section and 4.4

**R6:** IROL Stability Limit Violations is referenced in the EOM in Section 4.5

**R7:** High/Low Frequency is referenced in the EOM in Section 4.6

**Certified by:** Jon Sawyer

**Title:** Director, Grid Operations

**Date:** August 30, 2024