

<b>List of Potential Reliability Rule Changes - Outstanding</b>						
Categories: R = Rule; D = Definition; RO = Requirement; P = Procedure/Guideline; C = Compliance Elements; F = Exception						
Status: 1=In RRS for development/review 2=In RCMS for compliance elements 3=To EC for approval to post 4=Approved by EC for posting 5=RRS incorporating comments from posting 6=To EC for final approval 7=Approved by EC 8=Removed						
<b>PRR No.</b>	<b>Existing Rule</b>	<b>Potential Rule Change</b>	<b>Sponsor</b>	<b>Category</b>	<b>Status</b>	<b>RRS Action</b>
PRR 153	New Contingency requirement for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1.	Include "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1	NYISO/RRS/ EW WG	R	1	In development