NYISO OPERATIONS REPORT FOR the Month of OCTOBER 2024

Peak Load

The peak load for the month was 18,567 MW, which occurred Tuesday, October 22, 2024, for hour beginning 18:00. At that time, the Operating Reserve requirement was 1,965 MW. This resulted in a minimum total Operating Capacity requirement of 20,532 MW for that hour.

Reserve Requirements:

Reserve	10 sync	Non sync	30 min
Requirement	655	1,310	1,965
For Hour	1,354	2,229	3,454
DSASP Cont.	361	0	361

The NYCA all time Summer peak load of 33,956 MW, which occurred on Friday, July 19, 2013 for hour beginning 16:00

Major Emergencies

None

The Major Emergency state was declared 0 times during October of 2023

Alert States

- ON 3 OCCASIONS AN ALERT STATE WAS DECLARED:
 - 0 SYSTEM FREQUENCY 0 LOW 0 HIGH
 - 0 ACE GREATER THAN (+OR-) 500MW
 - 0 SHORTAGE OF 10 MIN SYNCHRONIZED RESERVE
 - 0 SHORTAGE OF 10 MIN TOTAL RESERVE
 - 0 ACTUAL FLOW EXCEEDING LTE FOR LESS THAN 5 MIN
 - 0 ACTUAL VOLTAGE BELOW PRE-CONTIGENCY LOW LIMIT
 - 0 EXCEEDING CENTRAL EAST VOLTAGE CONTINGENCY LIMIT
 - 0 EXCEEDING TRANSIENT STABILITY LIMIT
 - 0 NYISO COMPUTER PROBLEM
 - 0 NEIGHBORING SYSTEM 5% VOLTAGE REDUCTION
 - 0 EMERGENCY TRANSFER DECLARED
 - 3 GIC (SMD) ACTIVITY
 - 0 SEVERE WEATHER
 - 0 OTHER

The Alert state was declared 3 times during October of 2023

Thunder Storm Alerts

1 Thunder Storm Alerts were declared for the month of October for a total of 12.6 hours

Reserve Activations

ON 1 OCCASIONSRESERVES WERE ACTIVATED DURING THE MONTH:

- 0 LOSS OF NEW YORK CONTROL AREA GENERATORS
- 0 MAINTENANCE OF SYNCHRONIZED RESERVES
- 1 SIMULTANEOUS ACTIVATION OF RESERVES
 - 0 FOR ISO-NE
 - 1 FOR IESO
 - 0 FOR PJM
 - 0 FOR NYISO
 - 0 FOR NB
- 0 LARGE CONTROL ERRORS (ABOVE 200MW)
 - 0 LOAD PICKUP
 - 0 SCHEDULE CHANGE & LOAD PICKUP
 - 0 SCHEDULE CHANGE
 - 0 SCHEDULE CHANGE DUE TO TLR
 - 0 OTHER (FIXED GEN CHANGES / COMPUTER PROBLEMS)
- 0 OF THESE RESERVE ACTIVATION'S DID NOT RESULT IN THE ACE-CROSSING ZERO
- 0 OF THE NON-ZERO CROSSINGS REQUIRED ANOTHER RESERVE PICKUP TO BE INITIATED
- 0 NON-ZERO CROSSINGS WERE ASSOCIATED WITH A UNIT LOSS
- ON 8 OCCASIONS RESERVES WERE ACTIVATED DURING THE MONTH OF OCTOBER 2023
- 3 OF THESE PICKUPS WHERE FOR ACE.

Emergency Actions

Special Case Resources:	None
Emergency Demand Response Program:	None
Purchases:	None
Sales:	None

TLR 3 Declared

0 TLR Level 3's were declared for the month of October for a total of 0 hours

Inadvertent Accumulations for

September 2024

	Monthly <u>Accumulation</u>		End of Month <u>Balance</u>	
On-Peak:	-9,190	MWh	-79,868	MWh
Off-Peak:	-210	MWh	-21,651	MWh

NERC Control Performance

CPS1:	163.81 %
BAAL VIOLATIONS:	0

NERC/NPCC Reportable DCS Events

None