

Historic  
NYCA  
Capacity  
Parameters

Capability Year (May - April)	Base Case IRM (%)	EC Approved IRM (%)	NYCA Equivalent UCAP Requirement (%)	NYISO Approved J LCR (%)	NYISO Approved K LCR (%)	NYISO Approved G-J (%)
2000-2001	15.5	18.0		80.0	107.0	
2001-2002	17.1	18.0		80.0	98.0	
2002-2003	18.0	18.0		80.0	93.0	
2003-2004	17.5	18.0		80.0	95.0	
2004-2005	17.1	18.0	11.9	80.0	99.0	
2005-2006	17.6	18.0	12.0	80.0	99.0	
2006-2007	18.0	18.0	11.6	80.0	99.0	
2007-2008	16.0	16.5	11.3	80.0	99.0	
2008-2009	15.0	15.0	8.4	80.0	94.0	
2009-2010	16.2	16.5	7.2	80.0	97.5	
2010-2011	17.9	18.0	6.1	80.0	104.5	
2011-2012	15.5	15.5	6.0	81.0	101.5	
2012-2013	16.1	16.0	5.4	83.0	99.0	
2013-2014	17.1	17.0	6.6	86.0	105.0	
2014-2015	17.0	17.0	6.4	85.0	107.0	88.0
2015-2016	17.3	17.0	7.0	83.5	103.5	90.5
2016-2017	17.4	17.5	6.2	80.5	102.5	90.0
2017-2018	18.1	18.0	7.0	81.5	103.5	91.5
2018-2019	18.2	18.2	8.1	80.5	103.5	94.5
2019-2020	16.8	17.0	6.7	82.8	104.1	92.3
2020-2021	18.9	18.9	9.0	86.6	103.4	90.0
2021-2022	20.7	20.7	10.1	80.3	102.9	87.6
2022-2023	19.6	19.6	7.9	81.2	99.5	89.2
2023-2024	19.9	20.0	7.8	81.7	105.2	85.4
2024-2025	23.1	22.0	5.9	80.4	105.3	81.0
2025-2026	24.4	24.4		78.5	106.5	78.8