

| List of Potential Reliability Rule Changes - Outstanding | | | | | | |
|--|---|--|---------------------|-----------------|---------------|-------------------|
| Categories: R = Rule; D = Definition; RO = Requirement; P = Procedure/Guideline; C = Compliance Elements; F = Exception | | | | | | |
| Status: 1=In RRS for development/review 2=In RCMS for compliance elements 3=To EC for approval to post 4=Approved by EC for posting 5=RRS incorporating comments from posting 6=To EC for final approval 7=Approved by EC 8=Removed | | | | | | |
| PRR No. | Existing Rule | Potential Rule Change | Sponsor | Category | Status | RRS Action |
| PRR 153 | New Contingency requirement for B.1 - Transmission System Planning Performance Requirements, R1 - Transmission facilities in the NYS Bulk Power System shall be planned to meet the respective performance requirements in Table B-1 and supplemental performance requirements in Table B-2 for the contingency events as specified in Table B-1. | Include "Sudden loss of fuel delivery system to multiple solar & wind plants" as Category I & II Design Contingencies in Table B-1 | NYISO/RRS/ EW WG | R | 1 | In development |
| | | | | | | |