

# NYISO Self-Certification

## NYSRC Reliability Rule Reference:

### A.3: Review of Resource Adequacy

## NYSRC Requirement(s) for which compliance is being self-certified:

**R2.** The NYISO shall prepare a biennial NYCA Long-Term Resource Adequacy Assessment covering a ten-year look-ahead period. This assessment shall include findings from the latest NYISO Reliability Needs Assessment (RNA) or other comparable NYISO- approved resource adequacy review. A summary report covering this assessment shall be provided to the NYSRC in accordance with the following requirements:

**R2.1** The documentation for the NYCA Long-Term Resource Adequacy Assessment to be included in the summary report shall be consistent with the *NYSRC Guidelines for NYCA Long-Term Resource Adequacy Assessments*. The NYSRC may request the NYISO to provide, as needed, supplemental information to be included in the summary report.

**R2.2** If the NYCA Long-Term Resource Adequacy Assessment analysis shows that the NYCA system LOLE is not within the NYSRC Resource Adequacy Criterion in Reliability Rule A.1: R1.1 for any year during the 10-year study period, the NYISO shall identify the amount of compensatory MW capacity that would be needed to bring the NYCA LOLE to 0.1 days per year.

**R2.3** The NYISO shall submit the NYCA Long-Term Resource Adequacy Assessment every two years in accordance with NYSRC schedules.

## Measure:

<input checked="" type="checkbox"/> Full Compliance	<b>M2.</b> The NYISO submitted a NYCA Long-Term Resource Adequacy Assessment report, covering the ten-year period covered by the latest RNA, to the NYSRC in accordance with the R2 requirements and NYSRC schedules.
---	---

## Compliance Monitoring Process:

### Compliance Monitoring Responsibility:

- **M2:** RCMS

### Compliance Documentation Reporting Frequency:

- **M2:** Every other year in accordance with RCMS schedules.

### Compliance Reporting Requirements:

- **M2:** Long-Term Resource Adequacy Assessment Report.

**Levels of Non-Compliance:**

___ Level 1	<b>M2:</b> Not applicable.
___ Level 2	<b>M2:</b> A Long-Term Resource Adequacy Assessment report was submitted, but in was incomplete or not consistent with R2 requirements, including those reporting requirements included in the <i>NYSRC Guidelines for Resource Adequacy Assessments</i> .
___ Level 3	<b>M2:</b> Not applicable
___ Level 4	<b>M2:</b> A Long-Term Resource Adequacy Assessment was not submitted.

**Reliability Rule A.3 R2 Narrative:**

The Manager, Resource Planning oversees the preparation of an annual long term resource adequacy report derived from the NYISO bi-annual Reliability Needs Assessment and addresses the requirements in accordance with A.3.R2, or A.3.A3 (for non-RNA Intervening Years), as applicable. Please see the NY Long-Term Resource Adequacy Assessment for NYSRC.

**Certified by:** Laura Popa

**Title:** Manager, Resource Planning

**Date:** February 6, 2025