

NYISO Self-Certification

NYSRC Reliability Rule:

G.1: New York City System Operations

NYSRC Requirement(s) for which compliance is being self-certified:

R6. The *NYISO* shall have in place procedures to ensure that sufficient *ten (10) minute reserves* are maintained in the NYC *zone* in accordance with R3.

Measure:

<input checked="" type="checkbox"/> Full Compliance	M2. The <i>NYISO</i> has required procedures in place and operated the NYCA system to ensure implementation of R6.
---	---

Compliance Monitoring Process:

Compliance Monitoring Responsibility:

- **M2:** RCMS

Compliance Documentation Reporting Frequency:

- **M2:** In accordance with *NYSRC* Compliance Monitoring Program schedules.

Compliance Reporting Requirements:

- **M2:** *NYISO* Self-Certification

Levels of Non-Compliance:

<input type="checkbox"/> Level 1	M2: Not applicable
<input type="checkbox"/> Level 2	M2: The <i>NYISO</i> has required procedures in place, but they are incomplete in one or more areas.
<input type="checkbox"/> Level 3	M2. Not applicable.
<input type="checkbox"/> Level 4	M2. The required <i>NYISO</i> procedures not available or were not provided.

Reliability Rule G.1 R6 Narrative:

NYISO Emergency Operations Manual Section 4.4.1 “Shortage Operating Reserve New York City – Day-Ahead Forecast” is the procedure which addresses both day ahead and real time maintenance of ten (10) minute operating reserves in the NYC zone.

The NYISO Day-Ahead Market (Security Constrained Unit Commitment) monitors the requirement to meet the NYC zone ten (10) minute reserve requirement.

SCUC produces a daily report provided to the Operators which indicates if the NYC zone is deficient 10 Minute Reserve. The report is distributed with the daily SCUC documents to the Shift Supervisor.

Certified by: Jon Sawyer

Title: Director, Grid Operations

Date: April 3, 2025